

Sanitary Setbacks

Physical Feature	POWTS Treatment	Exterior Subsurface Treatment Tank or Holding Tank Component	Servicing, Suction lines and Pump Discharge Lines (Pressurized)	Privy
Accessory Building	10 feet	5 feet	5 feet	10 feet
Dwelling				25 feet
Property Line	5 feet	2 feet	2 feet	10 feet
Swimming Pool	15 feet	None	None	None
OHWB of Navigable Waters	50 feet	10 feet	10 feet	75 feet
Trout Stream Class I, II, or III				100 feet
Water Service and Private	10 feet	10 feet	10 feet	
Water Main				
Well	50 feet	25 feet	8 feet	50 feet
Privy	3 feet			

Other Setbacks

- Well to any structure – 2 feet
- Building Setback to property line – 10 feet
- Building Setback to OHWM – 75 feet
- Boathouse to OHWM – 6 feet